

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20170425-EX27362  
**Report Reference** EX27362-20170425  
**Issue Date** 2017-APRIL-25

**Issued to:** International Industries Limited  
LX 15-16, Landhi Industrial  
Area Karachi 75120 PAKISTAN

**This is to certify that  
representative samples of**

**METALLIC SPRINKLER PIPE**

Schedule 10 (Black or Galvanised) steel sprinkler pipe in the 3/4, 1, 1-1/2, 2, 2-1/2, 3, 3 1/2, 4, 5, 8 and 10 inch sizes.  
Schedule 30 (Black or Galvanised) steel sprinkler pipe in the 8 inch size.

Schedule 40 (Black or Galvanised) steel sprinkler pipe in the 1/2, 3/4, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6 and 10 inch sizes.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 852, Metallic Sprinkler Pipe for Fire Protection Service.

**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

